

Practical Energy Tips for Energy Savings in HVAC Systems: Down to Earth Sustainability

ASHRAE TC 7.6

Richard J. Pearson, P.E.
ASHRAE Fellow and Distinguished Lecturer

December 15, 2011

1

Learning Objectives

- Recognize the environmental and economic impacts of energy management
- Assess building energy performance and set energy usage goals
- Create an action plan for saving energy
- Prioritize multiple building projects
- Define accountability for a building's ongoing energy management

3

Sustaining our Future by Rebuilding our Past

“Energy Efficiency in Existing Buildings is Our Greatest Opportunity for a Sustainable Future”

Gordon Holness, ASHRAE Presidential Member

Our Greatest Opportunities

86% of Construction Dollars go into Existing Buildings

75% to 80% of All Buildings that will Exist in 2030 Exist Today!

Energy Management Potential

Building Reduction
33%



National Reduction
14%

In Other Words.....

- Green
- Sustainable
- Lowers Carbon Footprint
- Lowers CO₂ Emissions
- Reduces Global Warming
- Reduces Cost
- Improves Return on Investment

Emissions Factors and Energy Prices for the Cleaner and Greener Environmental Program
<http://www.cleanerandgreener.org/download/efactors.pdf>

14

Greener Pastures with Energy Savings Emissions Reduction at Madison Area Technical College

Energy	Usage FY 01/02	Usage FY 06/07	Reduction!
Electricity	23,000,000 kWh	18,000,000 kWh	5,000,000 kWh
Natural Gas	900,000 therms	645,000 therms	255,000 therms
Emissions	Emissions FY 01/02	Emissions FY 06/07	Reduction!
Carbon Dioxide	30,500 tons	23,000 tons	7,500 tons
Sulfur Oxides	138 tons	106 tons	32 tons
Nitrogen Oxides	72 tons	55 tons	17 tons

Source: MATC Engineering Manager – Wesley Marquardt –
wmarquardt@matcmadison.edu

For 50 state emissions data, refer to "Emission Factors and Energy Prices":
<http://www.cleanerandgreener.org/download/efactors.pdf>

15

GSA Energy Management Program

US Courthouse
Jacksonville, Florida
Constructed in 2005
Disappointing Energy Use

DOE-ORNL Report

17

2005 New Building Performance

- Floor area: 492,000 ft²
- EUI: 83 kBtu/SF predicted to be 45 kBtu/SF
- Energy Star rating: 41 predicted to be 79
- Utility costs: \$664,000/year predicted to be \$220,000/yr
- Far less efficient than design intent

More on this building later...

18

Energy Management Strategies

- Do Nothing
- Price Shopping
- Occasional O&M Projects
- Capital Projects
- **Sustained Energy Management**

Christopher Russel
www.energypathfinder.com

19

Energy Management 101



- Management commitment
- Manual daily meter reading
- Operational changes only
- **33% energy savings in 12 months**

23

Energy Management 101 The Building

20-Story Office Building:

- 200,000 ft²
- 5 years old, no energy conservation
- Complex, energy intensive HVAC systems
- High utility bills
- No building automation system

24



Energy Management 101 How It Worked

Actions by Facility Manager:

- Reviewed possible operational improvements with building engineer and design engineer
- Read meters daily
- Obtained previous day's weather data
- Harassed/complimented building engineer daily

Savings in one year: 33%!

25



Make Commitment

Top Management Commits to Continuous Improvement

The common element of successful energy management is commitment.

- Form a Dedicated Team
- Institute an Energy Policy

29

Energy Manager Job Description

Chapter 36, ASHRAE 2011 Handbook
“Energy Use and Management”

- Functions
 - Technical
 - Policy-related
 - Planning and purchasing
- Qualifications
 - General
 - Educational/Professional

30

Job Description - Purchasing

- Lower-cost energy
- Other non-building utilities
 - Vehicle fuel
 - Water

31

Energy Star Guidelines for Energy Management

www.energystar.gov



32

Assess Performance & Set Goals

33

Assess Performance & Set Goals

- Annual Usage
 - Energy Cost Index (ECI)
 - Energy Utilization Index (EUI)
- Annual Profile of Monthly Data
- Daily Profile of 15-Minute Data

35

Indices

ECI: Energy Cost Index = \$/SF/yr

EUI: Energy Utilization Index = kBtu/SF/yr

$$\frac{\text{(Annual kWh X 3.413)} + \text{(Annual Therms X 100)}}{\text{Total Annual Energy}} = \text{_____ kBtu}$$

EUI = Total Annual Energy ÷ SF = kBtu/SF/yr

Example: Lowell Hall @ UW, 1996


$$\frac{\text{(1,209,319 kWh X 3.413)} + \text{(83,642 Therms X 100)}}{\text{Total Annual Energy}} = 12,491,200 \text{ kBtu}$$

EUI = 12,491,200 kBtu ÷ 117,600 SF = 106.2 kBtu/SF/yr

36

Energy Intensity of Office Buildings

www.energystar.gov



37

Energy Star Benchmarking

www.energystar.gov/benchmark

38

PORTFOLIO MANAGER - QUICK REFERENCE GUIDE

Rate Your Energy Performance

Use this (2) Step energy performance rating system within Portfolio Manager to rate the energy performance of your office facilities on a scale of 1-100. Rate all of your facilities and submit the data regularly to keep current of your energy consumption. See page 16 for the eligibility and data needs.

USE PORTFOLIO MANAGER STEP-BY-STEP

STEP	ACTIVITY	ACTION
1	Access Portfolio Manager	www.energystar.gov/benchmark
2	Access your account	<ul style="list-style-type: none"> Click REGISTER and set "Basic User" Enter your name and password and click VERIFY Click the "Remember" option and click SIGN UP
3	Add a new property	Click ADD A PROPERTY on the "My Portfolio" page
4	Specify property type	Select the appropriate system and click CONFIRM
5	Enter general building data	Enter all required information and click SAVE
6	Enter system data	<ul style="list-style-type: none"> Click "System" and select the correct EUI (EUI2) Click a system name, enter the system EUI, and enter the system building data. Click CONFIRM Enter all required data. Click SAVE Repeat and repeat for each system and building. For more information, see "Building Data" section on this page.
7	Enter energy use data	<ul style="list-style-type: none"> Use "Energy Meter" section on this page and click VERIFY Click each meter, energy type, and unit. Repeat entering numbers for all meters of building. Click SAVE Click the total number of meters within a building. Click CONFIRM Enter energy use. Click SAVE Repeat for all other meters in building. At the top of the "Building Summary" page, review your results in the "Building Performance" section.
8	Review and complete results	<ul style="list-style-type: none"> Click any building and scroll to verify, update a Building of Energy Performance, and performance targets. Review, update for the ENERGY STAR, create a building audit, and update the other information.
9	Manage account and apply for recognition	

www.energystar.gov/benchmark

44

ENERGY SYSTEMS

- 10-10: This portion of an office building system (HVAC, lighting, etc.) is designed to be efficient. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment.
- 10-11: This portion of an office building system (HVAC, lighting, etc.) is designed to be efficient. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment.

ENERGY USE

- 10-12: This portion of an office building system (HVAC, lighting, etc.) is designed to be efficient. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment.
- 10-13: This portion of an office building system (HVAC, lighting, etc.) is designed to be efficient. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment.

REMARKS

- 10-14: This portion of an office building system (HVAC, lighting, etc.) is designed to be efficient. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment.
- 10-15: This portion of an office building system (HVAC, lighting, etc.) is designed to be efficient. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment. It is designed to be efficient, using high-efficiency lighting, motors, and other equipment.

45

Energy Star Portfolio Facility Summary

Facility Summary: Lowell Hall
 Building ID: 100112
 Level of Access: Building Data Administrator

Facility Performance	12 Months Ending	Total Energy (kBtu)	Actual Energy (kBtu)	Energy Intensity (kBtu/sq ft)	Energy Intensity (kBtu/sq ft)	Energy Use Index	Target	Score	Top	Flag
December 2011	12,796,888.26	148.3	N/A	N/A	N/A	120	Yes			
December 2010	13,963,638.06	170.0	N/A	N/A	N/A	120	Yes			

Energy Meter: 100112

System Name	System Type	System	Energy Intensity (kBtu/sq ft)	Score	Target
Lighting	Panel (Direct)	100112	15.128	84	120
Lighting	Other (General)	100112	16.418	81	120
Total			15.523	88%	

Energy Meter: 100112

System Name	System Type	System	Energy Intensity (kBtu/sq ft)	Score	Target
Electricity WWH (Residential)	Electric	100112	100.000	100	120
Electricity WWH (Commercial)	Electric	100112	100.000	100	120
Gas	Natural Gas (Thermal)	100112	100.000	100	120

46

Target Page in Portfolio Manager

http://www.energystar.gov/benchmark

Portfolio Manager - Facility Details

Set Energy Performance Baseline and Targets

You may establish an energy performance baseline and targets for either defining a target rating or target reduction. The energy use and costs displayed reflect required levels to meet either the target rating and percent reduction goal. Select "Show" to view the selected targets in Portfolio Manager.

Set Baseline (12 Months Ending)	December 2011	2012
Target (1,000 Buildings)	38	
Baseline Energy Use (kBtu/sq ft)	13,963,638	
Target Energy Use (kBtu/sq ft)	8,177,267	
Energy Cost Savings (\$/sq ft)	\$48,554	
Target Reduction (%)	41%	

47

Assess Performance & Set Goals

- Annual Usage
 - Energy Cost Index (ECI)
 - Energy Utilization Index (EUI)
- Annual Profile of Monthly Data
- **Daily Profile of 15-Minute Data**


52

Honolulu Office Building: Using 15-Minute Data to Identify Opportunities




53

Daily Profile of 15-Minute Data




54


Daily Profile of 15-Minute Data Honolulu Office Building



55



56




57

Create Action Plan

Where Do I Start Saving Energy?

58



60


Action Plan: Evaluating Multiple Buildings

Site	SF	Zone	Type	ECI	EUI	Current \$
601-Tyson's Corner	39,463	4	Homestore	\$3.01	193	\$118,823
510-Mission Viejo	12,895	4	Housewares	\$6.10	177	\$78,685
503-Fashion Valley	14,510	4	Housewares	\$6.66	177	\$96,579
412-Roseville	34,372	4	Homestore	\$4.13	176	\$142,059
851-Lenox	36,919	4	Homestore	\$3.21	175	\$118,325
855-Alpharetta	29,282	4	Homestore	\$2.52	156	\$73,674
511-South Coast II	36,417	4	Homestore	\$6.02	154	\$219,158
402-Corte Madera	11,632	4	Housewares	\$6.29	142	\$73,119
404 a - Santana Row	38,017	4	Homestore	\$5.96	140	\$226,467
507-University Town Centre	12,678	4	Housewares	\$5.33	137	\$67,561
406-Walnut Creek	37,552	4	Homestore	\$6.16	129	\$231,358
506-Pasadena	38,566	4	Housewares	\$3.11	121	\$44,383
506-Topanga Plaza	14,262	4	Housewares	\$3.11	121	\$44,383
860-Crabtree Valley	13,305	4	Housewares	\$1.86	115	\$24,761
411-Union Square Furniture	43,167	4	Homestore	\$4.91	114	\$211,820
502-Century City(Closed)	14,200	4	Housewares	\$2.10	79	\$29,763
407-Hillsdale	15,238	4	Housewares	\$3.24	71	\$49,341
403-Palo Alto	38,920	4	Homestore	\$0.86	40	\$33,588

Action Plan: Evaluating Multiple Buildings

Site	SF	Zone	Type	ECI	EUI	Current \$	New \$	Savings
601-Tyson's Corner	39,463	4	Homestore	\$3.01	193	\$118,823	\$70,678	\$48,146
510-Mission Viejo	12,895	4	Housewares	\$6.10	177	\$78,685	\$51,093	\$27,592
503-Fashion Valley	14,510	4	Housewares	\$6.66	177	\$96,579	\$62,924	\$33,655
412-Roseville	34,372	4	Homestore	\$4.13	176	\$142,059	\$92,740	\$49,320
851-Lenox	36,919	4	Homestore	\$3.21	175	\$118,325	\$77,619	\$40,707
855-Alpharetta	29,282	4	Homestore	\$2.52	156	\$73,674	\$54,176	\$19,498
511-South Coast II	36,417	4	Homestore	\$6.02	154	\$219,158	\$164,146	\$55,012
402-Corte Madera	11,632	4	Housewares	\$6.29	142	\$73,119	\$59,252	\$13,867
404 a - Santana Row	38,017	4	Homestore	\$5.96	140	\$226,467	\$185,686	\$40,781
507-University Town Centre	12,678	4	Housewares	\$5.33	137	\$67,561	\$56,700	\$10,861
406-Walnut Creek	37,552	4	Homestore	\$6.16	129	\$231,358	\$164,175	\$67,183
506-Pasadena	38,566	4	Housewares	\$3.11	121	\$44,383	\$24,761	\$19,622
506-Topanga Plaza	14,262	4	Housewares	\$3.11	121	\$44,383	\$24,761	\$19,622
860-Crabtree Valley	13,305	4	Housewares	\$1.86	115	\$24,761	\$13,305	\$11,456
411-Union Square Furniture	43,167	4	Homestore	\$4.91	114	\$211,820	\$114,220	\$97,600
502-Century City(Closed)	14,200	4	Housewares	\$2.10	79	\$29,763	\$14,200	\$15,563
407-Hillsdale	15,238	4	Housewares	\$3.24	71	\$49,341	\$33,588	\$15,753
403-Palo Alto	38,920	4	Homestore	\$0.86	40	\$33,588	\$33,588	\$0
						\$2,003,639		





Action Plan: Evaluating End-Use Within a Building




End-Use Evaluation

Use trend logs or portable data-loggers

- Runtime
- Temperature fluctuations
- Electrical use
 - Amps
 - kWh





Two Types of Action

- Discretionary Facility Operation
- Energy Audits and Capital Improvements

73



Wisconsin's Focus on Energy Best Practices Spreadsheets

- Air Handlers
- Boilers
- Chillers
- Cooking
- Domestic Hot Water
- HVAC
- Lighting
- Misc. Equipment
- Refrigeration

Available for download at:
<http://www.focusonenergy.com/business/commercial-business/cpem/sixsteps.aspx>

Air-Handlers Best Practices

- **Install Variable Speed Controls on Air Handler Supply Fan**
- Convert Air Handling system from Constant Volume to Variable Air Flow
- Convert Dual Duct or Multizone Air Handling System to Variable Air Flow
- **Install Premium Efficiency Motors**
- Install High Efficiency AC Units or RTUs
- **Reduce Outside Air Intake**
- **Install Night Setback Controls (Heating season)**
- **Install Night Set Up Controls (Cooling season)**

Air-Handlers Best Practices

Variable Speed Drive on an Air Handler

Converting an air handler from one type of control (constant volume to variable air volume) can save heating, cooling and fan energy. Fan energy savings only are calculated by this spreadsheet.

The heating and cooling energy savings are very dependent on type of air handling system, and how the system is operated. Therefore, those savings are not reflected in this spreadsheet.

Air-Handlers Best Practices

EXISTING		Proposed	
Motor Horsepower	3.0	2.0	2.0
Motor Efficiency	88.0%	90.0%	90.0%
% Full Load	100.0%	100.0%	100.0%
Annual Operating Hours	2,100	2,100	2,100
Conversion Factor	0.746	0.746	0.746
kW	2.6	1.5	1.5
kWh/yr	5,460	2,970	2,970
Average kWh Rate	\$0.10	\$0.10	\$0.10
Annual Energy Cost	\$546	\$297	\$297
Annual Energy Cost	\$546	\$297	\$297
Motor Horsepower	3.0	2.0	2.0
Motor Efficiency	88.0%	90.0%	90.0%
VFD Efficiency	98.0%	98.0%	98.0%
Conversion Factor	0.746	0.746	0.746
Savings Factor	1.00	0.59	0.59
Annual Energy Cost	\$546	\$297	\$297
Annual Energy Cost	\$546	\$297	\$297
Annual Cost Savings	\$249	\$249	\$249
Annual Cost Savings	\$249	\$249	\$249
Project Cost Estimate	\$1,000	\$1,000	\$1,000
Payback	4.0	4.0	4.0
Simple Payback	4.0	4.0	4.0

Install Variable Speed Controls on Supply Fan

Air-Handlers Best Practices

Premium Efficiency Motors

Premium efficiency motors will generally require a larger up-front investment. However, the incremental cost can usually be recovered in less than 2 years. Additionally, it is typically less expensive to purchase equipment with the premium efficiency component already installed than it would be to retrofit the equipment at a later time.

Air-Handlers Best Practices

Existing Motor		Example	Motor 1
Motor Horsepower		10.0	10.0
Existing Motor EPR		87.2%	87.2%
% Full Load		11.9%	12.1%
Annual Operating Hours		2,500	2,500
Conversion Factor		0.146	0.142
KW		5.8	5.6
kWh/yr		13,800	12,600
Average kWh Rate		\$0.001	\$0.000
Annual Energy Cost		\$1,412	\$1,112
PROPOSED			
Motor Efficiency		91.7%	91.7%
Conversion Factor		0.146	0.142
KW		5.3	5.3
kWh/yr		11,200	11,200
Annual Energy Cost		\$1,050	\$1,050
SAVINGS			
KW		0.5	0.3
kWh/yr		2,600	1,400
Annual Cost Savings		\$362	\$64.04
Project cost Estimate		\$610	\$300
Payback		1.7	0.5
Simple Payback		1.7	0.7

Install Premium Efficiency Motors

Air-Handlers Best Practices

Outside Air Reduction

Air handling units serve several functions including space heating, cooling and ventilation. Facility ventilation is generally accomplished by bringing in outside air, mixing it with "return air" at the air handler, and distributing the resulting "mixed air" throughout the facility. Bringing in outside air increases energy consumption during most times of year because the outside air needs to be conditioned. Therefore, it is important to make sure the correct amount of outside air is being supplied to the facility only when needed. Outside air is needed when the facility is occupied, or when large exhaust systems are being operated. The calculations below estimate gas savings associated with an outside air reduction. If the facility is cooled, and/or the ahu fans are shut down during times of reduced ventilation, then there will also be electrical savings.

Dick's Tips

1. Turn off unneeded exhaust fans
2. Do not open O.A. dampers until occupancy

Air-Handlers Best Practices

EXISTING		Example	Motor 1
CFM of Outside Air		1,000	10,000
AHU Motor Efficiency		87.2%	87.2%
AHU Motor Load Factor		11.9%	12.1%
Heating Coils in Supply		0.0	0.0
Heating Coils in Return		0.0	0.0
Heating Return Fan (1)		0.0	0.0
Heating Return Fan (2)		0.0	0.0
Heating System Efficiency		0.0	0.0
is the facility cooled		0.0	0.0
Cooling Return Fan		0.0	0.0
Cooling System Efficiency		0.0	0.0
CFM of Cooling System		0.0	0.0
Conversion Factor		0.146	0.142
Req. Size Unit (kW)		4.200	11.400
Average From Motor		8.400	16.200
Average kWh Rate		\$0.000	\$0.000
Annual Energy Cost		\$0.000	\$0.000
PROPOSED			
CFM of Outside Air		1000	1000
Heating Coils in Supply		0.0	0.0
Heating Coils in Return		0.0	0.0
Req. Size Unit (kW)		2.00	2.00
Average From Motor		4.000	4.000
Average kWh Rate		\$0.000	\$0.000
Annual Energy Cost		\$0.000	\$0.000
SAVINGS			
kWh		1,200	1,200
kWh/yr		1,200	1,200
Annual Cost Savings		\$1,200	\$1,200
Project cost Estimate		\$0	\$0
Payback		0.0	0.0
Simple Payback		0.0	0.0

Reduce Outside Air Intake

Air-Handlers Best Practices

Install Night Setback (heating) and Night Set Up (cooling) Controls

Setback Controls

Setback controls reduce the space temperature of an area during unoccupied hours. Reducing the temperature means less heat is lost to the outside through walls, roofs and air infiltration. Setback controls may be part of a facility-wide energy management system, or separate programmable thermostats may be used. Some setback controls employ "smart" features which determine when to start heating a building to make sure it is warm when occupancy starts. These "smart" controls look at both the outside air temperature and inside air temperature. Costs on controls can range from as low as \$40 for a programmable thermostat, to hundreds of thousands of dollars for complete energy management systems for facilities with multiple buildings.

Setup Controls

Set-Up controls allow the space temperature to float upward during unoccupied hours. Increasing the temperature means less heat needs to be removed from the building. Set-Up controls may be part of a facility-wide energy management system, or separate programmable thermostats may be used. Some controls employ "smart" features which determine when to start cooling a building to make sure it is at the correct temperature when occupancy starts. These "smart" controls look at both the outside air temperature and inside air temperature. Costs of controls can range from as low as \$40 for a programmable thermostat, to hundreds of thousands of dollars for complete energy management systems for facilities with multiple buildings. If the facility is assessed a demand charge, the setback period should end at least 15 minutes before the utility on-peak period.

Air-Handlers Best Practices

Install Night Setback (heating) and Night Set Up (cooling) Controls

EXISTING		Example	Area 1
Square Footage		10,000	10,000
Therms per year		18,000	9,500
Average Therm Rate		\$3,990	\$2,550
Annual Energy Cost		\$14,850	\$9,075
PROPOSED			
Degrees of Temperature Setback		10	10
Hours per week of Setback		168	168
Constant - total hours per week		168	168
Adjustment factor		0.43	0.43
Average Winter temperature difference		55	38
Percent Reduction		6.3%	6.3%
Average therm/Yr Use		13,220	8,414
Annual Energy Cost		\$13,811	\$8,278
SAVINGS			
th/yr		1,241	786
Annual Cost Savings		\$1,979	\$1,817
Project cost Estimate		\$1,000	\$1,000
Incentive		\$0	\$150
Simple Payback		0.5	0.6

EXISTING		Example	Area 1
Square Footage		10,000	10,000
Coolest City		Madison	Madison
Cooling Balance from F/H		80	80
Cooling Degree Days		905	7,998
Cooling kWh/yr		71,000	18,000
Average kWh Rate		\$0.250	\$0.250
Annual Energy Cost		\$1,775	\$4,500
PROPOSED			
Degrees of Temperature Setback		2	3
Hours per week of Setback		126	126
Constant - total hours per week		168	168
Effective Cooling Degree Days		210	2,124
Adjustment factor		0.43	0.43
Percent Reduction		14.2%	11.3%
Average kWh/yr Use		13,808	13,360
Annual Energy Cost		\$1,426	\$1,084
SAVINGS			
kWh/yr		3,483	1,480
Annual Cost Savings		\$971	\$239
Project cost Estimate		\$1,000	\$1,000
Incentive		\$0	\$250
Simple Payback		1.1	0.3

85

Boilers Best Practices

- Test and Adjust Burners
- Replace Boiler with High Efficiency Unit
- Reduce Steam Pressure
- Steam Trap Repair/Replace
- Isolate Unused Boiler(s)
- Install Heat Recovery on the Boiler Stack (Flue Gas Economizer)
- Install Variable Speed Pumping
- Reset Boiler System Hot Water Temperatures

86

Boilers Best Practices

Test and Adjust Boiler Burners

Combustion efficiency is primarily a function of the fuel to air ratio at varying boiler loads. If the fuel to air ratio is too rich or too lean, efficiency is negatively impacted. A good way to keep boilers operating near an optimal fuel to air ratio, is to have the boilers tested and adjusted annually.

87


Boilers Best Practices

EXISTING		Example	System 1
Existing Boiler Efficiency		80%	80%
Average Current therm/Yr Use		87,000	87,000
Average therm Rate		\$3,950	\$3,950
Annual Energy Cost		\$63,650	\$63,650
PROPOSED			
Est. % Increase in Efficiency		3.0%	2.0%
Proposed Efficiency		82.0%	82.0%
Proposed Therm Use:		85,366	85,366
Annual Energy Cost		\$62,698	\$62,698
SAVINGS			
th/yr		1,634	1,634
Annual Cost Savings		\$1,552	\$1,552
Project cost Estimate		\$750	\$750
Incentive		\$0	\$110
Simple Payback		0.5	0.4

Test & Adjust Boiler Burners

88

Existing Burner showing linkages for gas and combustion air.



89

Linkageless Burner Characteristics

- Measures O₂ in flue gas
- Separately modulates gas valve to control load and matches speed of combustion air fan to maintain optimum efficiency at all loads.
- Estimated original turndown is 3:1
- Realistic new turndown is 6:1 (can be 8:1)
- Original peak efficiency is 78% to 80%
- New efficiency at all loads is 83% to 85% 90

Analysis of Linkageless Savings

- Apparent efficiency improvement: 78%/80% to 83%/85%. This is a 6% improvement at peak load.
- O₂ trim and separate modulation maintain peak efficiency at ALL LOADS.
- Burner turns down to lower loads without cycling off, this minimizes purging.
- An apparent 6% improvement results in an actual improvement of 20% or better.

91

Linkageless Economics

- Installed Cost \cong \$30,000
- Gas saved (15,600 therms @ \$1) \cong \$15,600
- Simple Payback \cong 1.9 years

92

Boilers Best Practices

Reduce Steam Pressure

Steam plants for heating and process needs can often operate at a range of pressures. It is often most efficient to operate these systems at the lowest possible pressures. When a system is operated at lower pressures, the temperature of the steam is lower. This leads to decreased heat loss from steam pipes. It also leads to more efficient operation of the boiler or steam generator, because the difference in temperature between the flame and the steam / hot water temperature is greater at lower pressures, resulting in greater heat transfer. In this analysis, only the savings due to increased boiler efficiency is estimated.

93

Boilers Best Practices

	Example	Plant 1
EXISTING		
Boiler Plant Size (MBtu/h) Input	1,000	1,000
Average Boiler Load Factor	25%	25%
Steam Temperature (F)	274	274
Boiler Efficiency at 215F Steam	80.0%	80.0%
Boiler Efficiency at Steam Temp	78.3%	78.3%
Hardy Boiler System is Studied	8,760	8,760
Conversion Factor (Mcu/h/Th)	100	100
Average Existing th/yr	21,900	21,900
Average Item Rate	\$1,800	\$1,900
Annual Energy Cost	\$20,805	\$20,805
PROPOSED		
Steam Temperature	250	250
Boiler Efficiency at New Steam T	78.2%	78.2%
Average Proposed th/yr	21,550	21,550
Annual Energy Cost	\$20,473	\$20,473
SAVINGS		
th/yr	350	350
Annual Cost Savings	\$332	\$332
Project cost Estimate	\$0	\$1,220
Incentive	\$0	\$22
Simple Payback	Immediate	3.7

Reduce Steam Pressure

94

Boilers Best Practices

Steam Trap Maintenance

The primary function of steam traps is to keep steam within the steam-using coils and appliances until the steam has condensed. The resulting condensate (water) flows out of the steam trap and into a condensate return. Steam traps are notorious for mechanical failure. Traps can either fail "closed" where no water or steam passes into the condensate system, or can fail "open" when both steam and water are allowed to pass into the condensate tank. This wastes energy and increases the amount of makeup water and chemical treatment needed. Routine checks and maintenance, and replacement of steam traps can reduce malfunctions and save energy.

95

Boilers Best Practices

	Example	TRAP
EXISTING		
# Traps in System	30	30
Steam Loss Rate	12.0	12.0
BTU/hr	600	600
Boiler Efficiency	80.0%	80.0%
% of Traps Failed Open	10%	10%
# Traps Failed	3	3
Boiler Operating Hours	5,110	5,110
Conversion Factor	100,000	100,000
Average Existing steam loss, th/yr	3,473	3,473
\$/th	\$0,990	\$0,990
Annual Energy Cost	\$2,994	\$2,994
PROPOSED		
Adjustment Factor (the amount of steam loss that is actually wasted)	75%	75%
Average Proposed th/yr	543	543
Annual Energy Cost	\$538	\$538
SAVINGS		
Savings th/yr	2,930	2,930
Annual Cost Savings	\$1,548	\$1,548
Project cost Estimate	\$1,200	\$1,200
Incentive	\$0	\$354
Simple Payback	0.8	0.5

Steam Trap Maintenance

96

Boilers Best Practices

Isolate Boilers

Most facilities that use boilers for space heat have at least two units to provide redundancy, and efficient operation during milder weather. Often these boilers are not easily isolated from one another when only one unit is operating. The result is that the standby unit has hot water or steam circulating through it. Because of this, the standby unit is effectively heated to the same temperature as the active unit, and therefore has significant shell heat loss. Automatic valves can be put in to isolate boilers, when only one unit is firing. Or, one boiler can be manually isolated during the mild periods of the heating season to reduce shell losses.

Boilers Best Practices

	Example	System 1
EXISTING		
Ave. Boiler Rating (MBtu/h)	1,870	1,870
% Shell Losses at Ave. Boiler Rating	2.2%	2.2%
Boiler Steam or Water Temperature	221	221
Ave Temperature in the Boiler Room	70	70
Number of Boilers in the Plant	2	2
Hourly Boiler Plant Operation	3,840	3,840
Average Existing th/yr	4,409	4,409
Average therm Rate	\$1,020	\$1,020
Annual Energy Cost	\$4,348	\$4,348
PROPOSED		
# of Boilers to be Isolated	1	1
His/yrly Boilers will be Isolated	3,850	3,850
Proposed Therm Use	3,872	3,872
Annual Energy Cost	\$2,918	\$2,918
SAVINGS		
th/yr	1,387	1,387
Annual Cost Savings	\$1,329	\$1,329
Project cost Estimate	\$0	\$1,200
Incentive	\$0	\$158
Simple Payback	Immediate	0.8

Isolate Unused Boilers

Boilers Best Practices

Variable Speed Drive Pump on Chilled or Hot Water Pumps

Many existing systems water pumping systems are constant speed. By going to a variable speed drive system, pumping energy can be saved. Often this will involve a constant temperature water supply, possibly some valving changes, and control changes.

Boilers Best Practices

	Example	System 1
EXISTING		
Motor Horsepower	20	20
Motor Efficiency	88.4%	88.4%
% Full Load	80.0%	80.0%
Control Factor	100%	100%
Annual Operation Hours	8,760	8,760
Conversion Factor	0.746	0.746
kWh	11.0	11.0
kWh/yr	96,156	96,156
Average kWh Rate	\$1.00	\$1.00
Annual Energy Cost	\$7,888	\$7,888
PROPOSED		
Motor Horsepower	20	20
Motor Efficiency	88.4%	88.4%
% Full Load	80%	80%
Conversion Factor	0.746	0.746
Control Factor	75%	75%
kWh	11.0	11.0
kWh/yr	32,681	32,681
Annual Energy Cost	\$3,268	\$3,268
SAVINGS		
kWh	0.0	0.0
kWh/yr	63,475	63,475
Annual Cost Savings	\$6,620	\$6,620
Project cost Estimate	\$4,000	\$4,500
Incentive	\$0	\$544
Simple Payback	1.0	0.8

Install Variable Speed Pumping

Boilers Best Practices

Hot Water Reset

Hot water heating systems are generally controlled to maintain a constant hot water temperature throughout the year. Therefore, the hot water temperature is set to the highest temperature required by the building. While the building may need very hot water in the winter to satisfy heating demand, during milder conditions lower water temperatures can often be used. Controls can be installed on most boiler systems to reduce the hot water set point based on the outside air temperature - the warmer the outside air temperature, the cooler the hot water temperature. Depending on the type of boiler being used, minor plumbing changes may need to be made to prevent the boiler from being shocked by cooler return water. The main energy savings associated with this best practice, is a reduced uncontrolled heat loss from the hot water pipes. In the winter months, the heat loss from the system may actually help to heat the building. However, during milder times of year, the heat loss can contribute to building overheating. This can be an especially significant problem for buildings that employ summer reheat, and therefore must circulate hot water in the summer time.

101

Boilers Best Practices

Hot Water Reset

	System	System 1
EXISTING		
Fl. of Inlet Pipe	300	400
Average Pipe Diameter (inches)	2	2
Hot Water Temperature (F)	150	150
Heat loss rate	15	27
Heat/yr	5,760	9,720
Boiler Efficiency	80%	80%
% of Losses that Provide Useful Heat	80%	87%
Is a cooling system used when the space is heating?	Yes	Yes
EDR of Cooling System	12.2	12.2
Conversion Factor	100,000	100,000
Average Existing Heat	448	848
Average Heat Rate	29,774	51,933
MMBtu/yr	5,514	9,514
Average kWh Heat	24,082	42,082
Annual Energy Cost	\$388	\$717
PROPOSED		
Hot Water Temperature	150	150
Heat loss rate	15	27
Average Proposed Heat	318	618
Average Heat Rate	2,489	4,899
MMBtu/yr	4,489	7,899
Annual Energy Cost	\$420	\$780
SAVINGS		
Heat	1,300	1,300
MMBtu/yr	1,889	1,600
Annual Cost Savings	\$374	\$336
Project cost Estimate	\$1,200	\$1,200
Payback	66	67
Simple Payback	3.2	3.1

102

Chillers Best Practices

- High Efficiency Chillers
- Chilled Water Reset
- Chilled Water Pump VFD

103

Chillers Best Practices

Chilled Water Reset

Chilled water temperature is often kept at a fixed set point. However, chillers tend to operate more efficiently, and have more cooling capacity if they are operated at higher chilled water temperatures. To increase chiller efficiency, chilled water temperature can be adjusted automatically based on the outside air temperature.

Dick's Tips

1. Increase chilled water temp: save 1.5% power per 1°F
2. Decrease condenser water temp: save 1.5% power per 1°F

Extreme Example

Increase chilled water temp from 42°F to 48°F AND decrease condenser water temp from 78°F to 75°F:

SAVE 13.5% POWER

104

Chillers Best Practices

EXISTING		Example	System 1
Existing Air Conditioner Size	70	30	
Chilled Water Temperature	45	45	
Existing Air Conditioner Efficiency (EER/BSEER)	10.2	10.2	
CO ₂ Emissions	200	200	
Unit Conversion (kWh/kWh)	1.000	1.000	
kW			
kW/yr	23.8	22.8	
Average kWh Rate	25.176	24.739	
Annual Energy Cost	\$1,626	\$1,294	
PROPOSED			
Proposed Air Conditioner Size	30	30	
Proposed Air Conditioner Efficiency (EER/BSEER)	10.7	10.7	
Unit Conversion (kWh/kWh)	1.000	1.000	
kW			
kW/yr	22.4	22.4	
Average kWh Rate	20.887	20.187	
Annual Energy Cost	\$1,613	\$1,113	
SAVINGS			
kW			
kW/yr	1.4	1.4	
Annual Cost Savings	\$49	\$19	
Project Cost Estimate	\$1,000	\$1,000	
Incentive	\$0	\$174	
Simple Payback	7.0	5.7	

Chilled Water Reset

105

Chillers Best Practices

Variable Speed Drive Pump on Chilled Water Pumps

Many existing systems water pumping systems are constant speed. By going to a variable speed drive system, pumping energy can be saved. Often this will involve a constant temperature water supply, possibly some valving changes, and control changes.

106

Chillers Best Practices

EXISTING		Example	System 1
Motor Horsepower	20	20	
Motor Efficiency	88.4%	88.4%	
% Full Load	100%	100%	
Correction Factor	1.000	1.000	
Annual Operation Hours	8,760	8,760	
Conversion Factor	1.000	1.000	
kW			
kW/yr	31.0	31.0	
Average kWh Rate	30.640	30.560	
Annual Energy Cost	\$2,689	\$1,909	
PROPOSED			
Motor Horsepower	20	20	
Motor Efficiency	89.2%	89.2%	
% Full Load	85%	85%	
Correction Factor	0.950	0.950	
Conversion Factor	1.000	1.000	
kW			
kW/yr	21.0	21.0	
Average kWh Rate	19.481	19.481	
Annual Energy Cost	\$1,806	\$1,806	
SAVINGS			
kW			
kW/yr	10	10	
Annual Cost Savings	\$4,000	\$4,000	
Project Cost Estimate	\$4,000	\$4,000	
Incentive	\$0	\$2,124	
Simple Payback	1.0	0.5	

Chilled Water Pump VFD

107

Lighting Best Practices

- Compact Fluorescents
- LED Exit Lights
- Reduced Hours of Operation
- Occupancy Sensors
- Vending Machines
- T12 to High Performance T8s
- Metal Halide to High Performance T8s or T5s
- Task Lighting

108

Lighting Best Practices

Miscellaneous Equipment Best Practices

- **EnergyStar Computers & Monitors**
- **Replace Windows**
- **Vending Machine Occupancy Sensors**
- **Add Roof Insulation**
- **Reduce Infiltration**

Miscellaneous Equipment Best Practices

Computers and Monitors

Many computers and monitors today are "Energy Star Compliant". This means that the units have the ability to operate in a low power mode after a certain amount of inactivity. The computer and/or monitor will power up to its normal operational power at the press of a key or movement of the mouse. Many computers, especially those produced after July of 2000, can sleep "intelligently" on networks, such that they can be awoken by a command placed over the network. Often the energy star features of computers and monitors are not enabled leading to no savings. The process to enable the features is simple, and can lead to substantial savings for facilities with a large number of computers.

Miscellaneous Equipment Best Practices

	Existing	Proposed
EXISTING		
Quantity of Computers	1	1
Number of Monitors	1	1
Avg Computer Operating Hours	2000	2000
Avg Monitor Operating Hours	2000	2000
Energy Computer on	1.20	0.50
Energy Monitor on	0.20	0.10
% Cooling Energy	100%	100%
Conversion Factor	1.00	1.00
kWh Computer	2.40	1.00
kWh Monitor	0.40	0.20
kWh Total	2.80	1.20
Utility Monitor	1.20	0.60
Utility Total	4.00	1.80
Average kWh Total	4.00	1.80
Annual Energy Cost	\$177	\$81
PROPOSED		
Avg Computer Sleep Hours	2000	1000
Avg Monitor Sleep Hours	2000	1000
Energy Computer in Active/Standby	1.20	0.50
Energy Monitor in Active/Standby	0.20	0.10
% Cooling Energy	100%	100%
Conversion Factor	1.00	1.00
kWh Computer	2.40	1.00
kWh Monitor	0.40	0.20
kWh Total	2.80	1.20
Utility Monitor	1.20	0.60
Utility Total	4.00	1.80
Gas Infrared Energy	0.00	0.00
Average kWh Total	4.00	1.80
Annual Energy Cost	\$177	\$81
SAVINGS		
kWh	2.80	1.20
Utility	4.00	1.80
(See Unit Sheet)		
Annual Cost Savings	\$177	\$81
Project Cost Estimate	\$0	\$1,000
Payback Period	0.00	12.5
Simple Payback	0.00	12.5

[EnergyStar Computers & Monitors](#)

Miscellaneous Equipment Best Practices

Install Occupancy Sensors on Vending Machines

Vending machines typically operate 24 hours a day, seven days a week. There are a number of products available that turn off the vending machine using an occupancy sensor. When no one is near the machine for a preset amount of time, the unit turns off. When someone walks by, the unit turns on. These devices are also set up to make sure that the machine maintains beverages at a low temperature. Occupancy sensor units for vending machines typically cost ~\$160 per unit.
 Rule of Thumb: Installing an occupancy sensor device on a vending machine can typically save \$50-\$120/machine/year depending on the type of unit and amount of people traffic by the unit. Simple payback range, 1.5 - 4 years.

113

Miscellaneous Equipment Best Practices


	Example	Area 1
EXISTING		
Number of Vending Machines:	8	8
% Useful Heat:	31%	20%
% AC Savings:	15%	11%
kW/yr saved per machine:	1,800	1,800
kW	Example	Area 1
kWh/yr	17,424	17,424
Average kWh Rate	\$1.00	\$1.00
Gas Increase (\$/yr)	288	288
Average Energy Rate	\$1.60	\$1.50
Annual Energy Cost	\$2772	\$2772
PROPOSED		
kW	Example	Area 1
kWh/yr	8	8
Gas Use (\$/yr)	0	0
Annual Energy Cost	\$8	\$8
SAVINGS		
kW	Example	Area 1
kWh/yr	17,424	17,424
Gas Use (\$/yr)	288	288
Annual Cost Savings:	\$2764	\$2764
Project cost Estimate	\$1,000	\$1,000
Incentive	\$0	\$131
Simple Payback	1.4	1.1

Vending Machine Occupancy Sensors

114

Wisconsin's Focus on Energy Best Practices Spreadsheets

Available for download at:
<http://www.focusonenergy.com/business/commercial-business/cpem/sixsteps.aspx>



115

Sample Discretionary Action Plan - Lighting

- Match operating hours to activities
 - Unoccupied Lighting
 - Existing Custodial Lighting
- Add Occupancy Sensors
- Assure Footcandles Appropriate for Tasks
- Install Efficient Light Sources
- Use lamps with higher Kelvin temperature ratings (recommended: 4100°K- 6500°K)

116

Sample Discretionary Action Plan – Air Systems

- Match running time to activities
- Lower hot air temperatures
- Raise cold air temperatures
- Lower fan pressure in ducts
- Adjust static pressure setpoints
 - Manual reset
 - Dynamic reset using damper positions
- Minimize outside air quantities
- Minimize exhaust quantities
- Match ventilation to number of occupants
- De-energize exhaust fans and close dampers when unoccupied

117

Sample Discretionary Action Plan – Air Systems

- Make best use of economizer operation
- Eliminate simultaneous heating and cooling
- Reduce airflow in constant volume (CV) systems
- De-energize nonessential loads
- Seal leaky ducts
- Convert CV systems to VAV

118

Sample Discretionary Action Plan – Pumping Systems

- Convert CV system to variable flow
- Install variable frequency drives
- Match running time to activities
- Verify proper flow
 - Throttle balance valves
 - Trim pump impellers
- Lower pressure setpoint to optimize variable flow
 - Manual reset
 - Dynamic reset
- De-energize nonessential loads

119

Sample Discretionary Action Plan – Boilers

- Lower hot water temperatures
- If steam, lower steam pressure
- Install modulating burners (linkage-less)
- Optimize boiler sequencing
- Minimize losses in de-energized boilers

120

Sample Discretionary Action Plan – Chillers

- Match running time to activities
- Raise chilled water setpoints
- Reduce condenser water temperature
- Optimize cooling tower fan speed
- Optimize chiller staging
- Minimize chiller cycling
- Reduce chilled water speed

121

ENERGY AUDIT CHECKLIST				
C. HVAC – COOLING	Does this problem exist?		Recommended	
	Y	N	Y	N
13. Control devices are not inspected on a regular basis. Recommended ICM: a. Inspect all air flow coils and other control equipment the proper number, frequency and time and the right order (from programming of all air units. Protect from unauthorized adjustments). Recommended ECM: a. Use an automated energy management system.	1.1	1.1	1.1	1.1
14. Building temperatures are not adjusted for unoccupied periods. Recommended ICM: a. Reduce thermostat settings by a minimum of 1°F at night, the weekend and holidays during heating season, but maintain comfort. b. Set device air conditioning units at night, on weekends and holidays. Recommended ECM: a. Install automatic controls such as time clocks or automated management systems.	1.1	1.1	1.1	1.1
15. Unoccupied or 100% load zones are heated or cooled unnecessarily. Recommended ICM: a. Reduce thermostat settings to 1°F in unoccupied zones. b. Where possible, turn off heating systems if cooling, or space use drops. c. Use setback/override in large spaces with low occupancy? d. Increase thermostat settings, to unoccupied areas, if possible. Recommended ECM: a. Install systems controls to reduce heating/cooling of unoccupied zones.	1.1	1.1	1.1	1.1
16. Heating/cooling equipment is started before occupancy and/or is operating during last hour of occupancy. Recommended ICM: a. Equipment will shut off three and a half hours of operation to determine whether control needs are complete. Adjust on wall of heating and cooling during the last hour of occupancy, allowing for building "mass". Recommended ECM: a. Install space clocks or an automated energy management system that will reduce heating and/or cooling. Maximize contribution rates.	1.1	1.1	1.1	1.1

Available at: <http://www.energy.wsu.edu/ftp-ep/pubs/rem/energyaudit/OMchecklists.pdf> 122




ENERGY AUDIT CHECKLIST				
C. HVAC – COOLING	Does this problem exist?		Recommended	
	Y	N	Y	N
18. Multiple air conditioning compressors start simultaneously. Recommended ICM: a. Adjust controls to stagger compressors. Recommended ECM: a. Install automatic controls that start, purchase and install. This will allow compressor #2 start to allow compressor #1 run longer after space conditioning load.	1.1	1.1	1.1	1.1
19. Chiller evaporating and condensing temperatures are not optimized. Recommended ICM: a. Increase chiller evaporator temperature following manufacturer's recommendations. b. Decrease chiller condensing temperature following manufacturer's recommendations.	1.1	1.1	1.1	1.1
21. Chiller is operating during cold weather to provide air conditioning. Recommended ICM: a. Provide a water temperature system (igniting cooling tower condenser water directly on the chiller's condenser coils). Raise the cooling and condensing water set temperatures. Also provide free cooling. Special care must be taken to heating and chiller condenser rates. b. If system is based on, using DX coils and air cooled condenser, track condenser cycle to reduce free cooling.	1.1	1.1	1.1	1.1
22. Refill coils are used to maintain zone temperatures. Recommended ECM: a. Convert to variable air volume systems if the refill coils are not necessary to supply heat during the heating season.	1.1	1.1	1.1	1.1
23. Building utilizes a dual duct or induction system. Recommended ECM: a. Convert dual duct or induction systems to variable air volume, if building has a constant heating season. b. Install controls to automatically reset hot and cold deck temperatures.	1.1	1.1	1.1	1.1

123

Additional Discretionary Opportunities

- Chapter 36, ASHRAE 2011 Handbook "Energy Use and Management"
- Washington State University Checklist <http://www.energy.wsu.edu/ftp-ep/pubs/rem/energyaudit/OMchecklists.pdf>
- Advocate EM Operational Checklist (handout)

124



Incentives for the Building Engineer

- Regular monitoring by the manager
- Managerial encouragement to experiment
 - Occasional, brief discomfort is OK
- Teamwork


132

Two Types of Action



- Discretionary Facility Operation
- Energy Audits and Capital Improvements

133



A LEED EB Reference


134

Levels of Effort

- Preliminary Energy Use Analysis
- Level I – Walk-Through Analysis
- Level II – Energy Survey and Analysis
- Level III – Detailed Analysis of Capital-Intensive Modifications


140

“Typical” Office Building End-Use



146


Honolulu Office Building Actual End-Use



147

Energy Star Guidelines for Energy Management

www.energystar.gov




Accountability

148

Evaluate Progress

149

Honolulu Office Building After



150

What We Did

- Capital – more efficient chillers, pumps, towers; new building automation system to integrate equipment operation
- Operational changes – matched schedules to occupancy
- Simple Payback: 5 years

151

Honolulu Office Building: Energy Management Results





- 20% energy savings
- Savings per year
 - \$100K
 - 750 tons CO₂
 - 2.3 tons NO_x
 - 2.0 tons SO₂

152

Madison Insurance Company



153



GSA Energy Management Program: The Rest of the Story

US Courthouse
Jacksonville, Florida
Energy Improvements

DOE-ORNL Report

2005 New Building Performance

- Floor area: 492,000 ft²
- EUI: 83 kBtu/SF – predicted to be 45 kBtu/SF
- Energy Star rating: 41 – predicted to be 79
- Utility costs: \$664,000/year – predicted to be \$220,000/yr
- **Far less efficient than design intent**

ECMs Implemented

- VAV minimum settings reduced to 10%
- Boilers turned off in summer
- Duct static pressure setpoints reduced from 1.5 in. to 0.7 in.

158

Results of Control Modifications

- EUI: 45 kBtu/SF – Reduced from 83
- Energy Star rating: 79 – Improved from 41
- Energy Savings: 11.7 trillion Btu/year
- Cost savings: \$220,000/year

Energy Star Plaque is now in the lobby!

159



Downtown Chicago Energy Star Building



Uninsulated concrete
Single pane glass


160

Madison Bank



161


Annual Profile of Monthly Peaks (kW)



Chillers add 500 kW in summer

162


Annual Profile of Monthly kWh



Fans waste energy in winter!

163

Evaluate Progress 3 Years Later



Energy Management Did Not Work!

164


Explanation of the failure to see progress at Madison Bank

- The high electrical energy use in colder months results from decision to maintain fans "on 24/7":
- No commitment to improve energy use
- No accountability

Therefore, NO CHANGE.

165

But Things Have Changed!




BREAK!


Unique Process using daily energy data

- Collect one year's utility data
 - Electric interval data (15 min or 30 min)
 - Daily natural gas (or steam) consumption
- Plot daily consumption versus Outside Air Temperature
 - Establish a model of each building normalized for weather
 - Weekend usage slightly different than weekday usage

176



177



7% savings in 12 months: \$89K and 530 Tons CO₂

Date	OA Temp	OA Dew Point	Actual Boiler CCF	Predicted CCF	Percent	Savings CCF	Actual Electric kWh	Predicted kWh	Percent	Savings kWh
1/1/2006	33.6	33.6	3,958	4,141	95.6%	183	47,958	49,045	97.8%	1,087
1/2/2006	38.6	38.6	3,891	3,939	98.8%	48	49,774	54,578	91.2%	4,804
1/3/2006	38.3	38.3	3,698	3,957	93.5%	258	53,456	54,578	97.9%	1,122
1/4/2006	38.9	38.9	4,189	3,921	106.8%	-268	53,936	54,578	98.8%	642
1/5/2006	34.5	33.3	4,943	4,196	117.8%	-747	54,140	54,578	99.2%	438
1/6/2006	28.3	24.6	4,758	4,616	103.3%	-152	52,441	54,578	96.1%	2,137
1/7/2006	31.5	30.7	4,545	4,273	106.4%	-272	48,894	49,045	99.7%	151
1/8/2006	34.2	33	4,492	4,104	109.4%	-388	48,255	49,045	98.4%	790
1/9/2006	34.1	33.1	4,832	4,222	114.5%	-610	53,642	54,578	98.3%	936
1/10/2006	24.6	23.3	4,303	4,887	88.1%	584	54,025	54,578	99.0%	553
12/21/2006	37.6	35.7	4,323	4,000	108.1%	-323	54,332	54,578	99.5%	246
12/22/2006	42.7	42.3	3,379	3,698	91.4%	319	53,468	54,578	98.0%	1,110
12/23/2006	37.3	35	3,970	3,919	101.3%	-51	48,990	49,045	99.9%	85
12/24/2006	33.6	25.5	3,766	4,141	91.7%	342	48,222	49,045	98.3%	823
12/25/2006	33.8	30.1	3,998	4,241	94.3%	243	47,188	54,578	86.5%	7,390
12/26/2006	29.6	23.5	4,234	4,525	93.6%	291	52,071	54,578	95.4%	2,507
12/27/2006	31.4	24.7	3,741	4,401	85.0%	660	52,698	54,578	96.6%	1,880
12/28/2006	37.6	32.8	3,357	4,000	83.9%	643	53,081	54,578	97.3%	1,497
12/29/2006	38.7	37.1	3,503	3,933	89.1%	430	52,867	54,578	96.9%	1,691
12/30/2006	34.7	33.9	3,236	4,074	79.4%	838	49,211	49,045	100.3%	-165
12/31/2006	43	41	3,243	3,600	90.1%	357	49,071	49,045	100.1%	-26
Totals			1,168,973	1,258,107	92.9%	89,214	21,925,821	21,602,617	101.5%	-323,204

Extra Benefit:
An Energy Management Breakthrough

Day	Outside Air Temp Deg F	Gas			Electric			Comment
		Calculated Usage CCF	Actual Usage CCF	Difference %	Calculated Usage kWh	Actual Usage kWh	Difference %	
8/9/2006	81.1	2,749	2,301	83.7	62,238	63,894	102.7	Sat
8/10/2006	81.0	2,753	2,360	85.7	62,137	64,323	103.5	Sat
8/11/2006	69.8	2,759	3,338	83.2	67,354	79,286	104.4	
8/12/2006	64.5	2,644	2,129	79.9	71,548	74,922	105.5	Rained all Day
8/13/2006	60.7	2,803	2,348	83.8	67,255	69,804	103.8	
8/14/2006	60.7	2,718	2,374	87.3	69,251	76,119	101.3	
8/15/2006	65.3	2,810	2,846	109.1	71,896	73,333	102.0	
8/16/2006	69.9	2,410	2,823	117.1	71,141	71,129	100.0	
8/17/2006	72.3	2,325	2,734	117.6	73,555	73,354	99.7	Sat
8/18/2006	59.8	2,842	2,134	110.3	66,348	66,540	100.3	Correct chiller problems
8/19/2006	52.0	3,205	2,345	73.2	58,571	55,413	94.6	Chillers off most of the day
8/20/2006	51.6	3,224	2,384	74.3	58,181	57,429	98.7	
8/21/2006	55.5	3,035	2,393	78.9	62,104	61,892	99.7	
8/22/2006	62.0	2,747	2,213	80.7	66,562	69,437	101.3	
8/23/2006	62.1	2,710	2,495	88.8	63,215	65,916	104.3	Sat
8/24/2006	58.1	2,876	2,470	85.9	59,176	60,878	102.9	Sun
8/25/2006	58.1	2,817	2,357	80.8	64,659	62,718	97.0	

- ### Applying the Process
- Aurora Health Care – 2009**
- 17 facilities
 - 7 million sq. ft.
 - Each facility joined the Portfolio Manager® system
 - President of Aurora Healthcare signed an EnergyStar® commitment to reduce energy 12% in 3 years
 - Each facility utilizes the spreadsheet and records energy consumption daily
 - Monthly summaries distributed to all
 - Monthly energy initiative meeting to share successful ideas

Aurora Health Care 2009-2010 Utility Summary

Facility	Sq Ft	%	2009-2010 Total		
			CO2 DfY (lbs)	2009 EUI (kBtu/sq ft)	2010 EUI (kBtu/sq ft)
Strology	278,100	89.4%	2,368,873	264.6	234.7
Westpark	150,000	100.0%	1,440,270	288.0	278.1
Truist Route	183,900	67.0%	1,587,847	367.3	345.4
West Aisle Methodist	848,443	100.0%	6,885,588	277.3	268.7
Bayland Clinic	810,748	100.0%	1,570,593	273.8	258.1
St. Luke's South Shore	360,000	100.0%	4,189,804	242.8	232.8
St. Luke's Medical Center	460,000	100.0%	11,718,418	254.7	214.7
Harlingen	200,000	100.0%	1,186,258	178.4	203.5
St. Luke's ★	1,719,189	91.1%	16,163,826	222.6	203.9
Kansas	330,000	99.9%	1,614,300	201.4	194.7
Delaware	410,000	84.0%	4,840,028	205.9	187.4
Bumby	780,501	98.1%	2,223,173	194	192.8
Lakeland	296,283	87.3%	1,633,713	129.2	148.9
Hot (Removed Laundry)	113,000	84.4%	6,568,997	211.2	228.8
Hot	11,000	100.0%	278,083	204.0	193.3
Corporate Building	21,000	81.3%	334,268	178.5	164.7
Dispensary Hospital	208,074	90.4%	80,385	81.8	85.4
Forest Home ★	136,000	89.2%	4,098,176	83.0	74.0
Total	7,687,303	93.4%	67,861,601	227.8	207.8

★ Achieved EnergyStar Award!


Highlighted buildings are not acute care hospitals

- Savings:**
- 7.6% reduction in energy usage
 - 67,567,601 lbs. reduction in CO₂ emissions

183


Aurora Health Care 2009-2010

- 7.6% reduction in energy consumption
- 67.6 million pound reduction in CO₂
- Two facilities achieved ENERGY STAR



184

Equivalent Revenue per \$10,000 savings for Acute Care Hospitals



Source: Corporate Realty, Design, & Management Institute

185

Energy Management Strategies Taken

- Chiller operations
- H.W. reset schedules
- Run schedules (occ./unocc., day/night, summer/winter)
- D.A. temperature reset schedules
- Steam pressures
- Installation of variable speed drives
- Isolation dampers for unoccupied areas
- Steam trap survey
- Shutting off air handling units in unoccupied areas.
- Maintaining modified space temperatures
- Promoting the energy message at department meetings

186

Reverse Energy Audit Process

- Low cost actions decrease utility costs first
- First steps reveal specific needs for future capital improvements
- In-depth audit and capital improvements follow

189



Energy Management at Monona Terrace Convention Center

Jeff Griffith
Building Maintenance Supervisor

- Action Plan
- Monitoring
- Benchmarking
- Accountability

191

Action Plan

- Initial commissioning by staff
- No compromise in customer comfort
- Eliminate simultaneous heating and cooling
- Adapt operation to daily schedule
- Eliminate energy use in unoccupied spaces
- Regular reminders to entire staff


192

Regular Monitoring

- Weekly energy review by engineering staff
- BAS alarms to pagers
 - Demand exceeds 1,100 kW
 - Chilled water exceeds 50°F
- Personal attention by one engineer on peak days

193

Monitoring and Benchmarking



194

Benchmarking

	Square Footage	Electricity (kbtu/sqft)	Net Gas (kbtu/sqft)	Steam (kbtu/sqft)	Chilled Water (kbtu/sqft)	Total Energy (kbtu/sqft)
Rochester, NY	200,000	55.78	0.00	0.00	0.00	55.78
Pittsburg, PA	1,500,000	24.05	0.00	32.25	108.46	162.75
Collinsville, IL	72,500	102.42	68.39	0.00	0.00	171.81
Rochester, MN	191,531	79.50	4.77	89.98	0.00	174.65
Milwaukee, WI	667,475	65.23	2.16	80.08	0.00	147.48
Madison, WI	303,000	51.08	9.51	4.91	0.00	65.50
Sarasota Springs, NY	52,500	68.23	89.81	0.00	0.00	156.04
Toledo, OH	325,000	39.72	73.74	0.00	0.00	113.46
Davenport, IA	154,215	45.28	81.37	0.00	0.00	126.62
Totals	3,466,221					

195

Accountability

- Jeff is personally accountable to the facility manager
- Engineering staff is accountable to Jeff and to each other
- Entire staff maintains an energy conscious culture
- Weekly staff review of energy use

196




Monona Terrace LEED EB Silver Certification

- Significant energy savings
- Non-toxic cleaning products
- Use of clean energy
- High recycling rates

197

Accountability: A Management Challenge



198

Defining Accountability

- Is a person answerable for the results?
- A building or a department can't be!

199



- Headquarters in Fond du Lac, Wisconsin
- Manufacturing and sales organization
- Multiple facilities across the US
- Multi-million dollar utility bill
- Jerry Eaton – Energy Manager
- >\$1 million annual savings

200

Jerry Eaton's Discoveries

- Utility cost was an overhead item – not a manageable expense
- Stickers on light switches – no impact on expense or consumption

201

Jerry Eaton's Parallel Activities

Developed a corporate-wide chain of accountability:

- ✓ Begin with buildings (each with a meter)
- ✓ Then departments within buildings (each with a meter)
- ✓ Appoint a person in each location to be responsible for proven results

202

Jerry Eaton's Parallel Activities

Developed an accountability process in which results are reviewed and discussed on a regular basis:

- ✓ In this context, "regular basis" is not defined as every 12 months. That feedback interval is too long.
- ✓ A monthly interval is reasonably functional.
- ✓ Some type of weekly review has proven to be very effective.

203

Jerry Eaton's Parallel Activities

Found waste and inefficiencies

Found ways to be more efficient

Developed a significant sub-metering program

Developed procedures to monitor the meters on a regular basis

204

Jerry Eaton's Success Story

- The cost of energy ceased to be an overhead item.
- Buildings and departments learned that their annual budgets had increased by approximately the amount of the cost of energy attributable to each entity.
- Energy teams were developed in each entity, coordinated by the energy manager.
- The "buck" stops at one person in each entity, who receives regular data from ongoing monitoring and measuring performed by the energy manager.
- Annual savings of over \$1 million.

205

Meters and Sub-Meters

- Meters by themselves do not save anything
- No direct payback on the purchase of a meter
- That is not the basis for their justification as an energy conservation investment
- Question: How can you manage it if you can't measure it?


206

Measurement Technology

- Measurement technology is continuously improving, and becoming more affordable
- More than one way to develop measurements which are useful in an Energy Management program
- Creative thinking and competitive bidding can produce surprising results

207

Energy Management is the Quickest, Cheapest, Cleanest Way to Extend World Energy Supplies



Energy management can provide three times the environmental impact of renewable energy

208

Successful Energy Savings Are Within Your Reach!

- Personal, regular attention of a single person
- Team-oriented atmosphere tends to ensure conservation
- Consider tying success to department perks or bonuses

209

Prepare for Culture Change — What You Can Do...

- Collect 24 months of utility bills
- Enter utility information into Energy Star Portfolio Manager and get your score as a baseline
- Review the Discretionary Action Plans (slides 116-124)
- Try one change — save some energy, reduce climate impact and build your confidence to deploy on-going Energy Management

210

Remember to Monitor!!



211

References

Text and on-line references are listed in the References supplement

212

About the Speaker

Richard J. Pearson, P.E.
ASHRAE Fellow and Distinguished Lecturer

Principal of Pearson Forensic Engineering, Madison, Wisconsin
dick@pearsonfe.net

Principal Contributor – ASHRAE Publications
Procedures for Commercial Building Energy Audits, Second Edition (2011)
Energy Use and Management Chapter (36), ASHRAE Handbook (2011)

Lead Instructor – University of Wisconsin College of Engineering
Department of Engineering Professional Development – Fundamentals of
Energy Auditing Course

Member of the National Register of Peer Professionals
Conducts Peer Reviews of GSA design projects for US courthouses, etc.

213

Questions?

215